

## Jason Burford

---

**From:** Fiume, Christopher <Christopher.Fiume@erie.gov>  
**Sent:** Tuesday, November 18, 2025 3:30 PM  
**To:** Jason Burford  
**Subject:** RE: Preliminary sanitary plans - Quaker Road, Town of Aurora

**Follow Up Flag:** Follow up  
**Flag Status:** Completed

Jason,

Just a thought before we go down the sewerline extension route:

I was talking with my boss and, if the owner can get an easement from the neighbor (technically two parcels but same owner), the DSM will allow a bore directly into the manhole as shown below. The entire run can be a private 6" lateral. This would eliminate the DSCA and make the State Highway permit easier to acquire as you will no longer be digging up any section of the road.

All of the work is possible with one borehole in the grass space on the neighboring parcel and one trench/bore pit on the proposed Dental Office parcel.



Let me know if you want to look into this or want the nodes assigned instead for the sewerline extension.

Thanks,